

CHL 001

Ultrasonic level measurement



DESCRIPTION

Max. distance measurement : 15m

Minimum distance measurement: 0,6m

5° beam angle

SAP 1000 timer included

Supply 11.4 ...40VDC, 11.4...28VAC

PHOTOS

